

REPORT OF FIRE

COAL MINES Works

Date 1-3-1934

Occurred Friday day January month 3 date 11.30 P.M. hour

Bldg. No. 419 Floor Cow Barn Occupied as NONE

Discovered by Residence Telephone No. 43

Turned in by Residence at 11.30 P.M. hour

Duration of fire about 20 minutes

Water Pressure 170 lbs Ample yes

When was full protection restored (Date and time) at once

Did Works Fire Dept. respond promptly? yes about 10 min

What equipment was used all Equipment was used

at #31 and #32 Hose House #31 Hose House  
500 feet 2 1/2" Hose #32 - 250 feet 2 1/2" Hose

Was any equipment found defective? No.

Estimated Damage 71.00

Probable cause must of been caused by some one

throwing a cigarette cigar or match  
in this Barn. no mizy or stove in this Building  
Who directed fire extinguisher? NONE USED

Remarks: (Including suggestions on how to prevent recurrence)

Hose was used By residents and Fire Department.  
Fire Sires was heard all over town.  
motor hose truck Responded about 5 minutes  
after alarm was sounded.