

B-11 2.9.71

INLAND STEEL COMPANY
WHEELWRIGHT, KENTUCKY

BLACK-OUT REGULATIONS FOR WHEELWRIGHT & PRICE, KENTUCKY

In the event of an alert warning of an impending bombing or attack by an enemy force, black-out procedure as outlined herein will be put into effect.

It will be the responsibility of the person first notified by an outside agency to, in turn, promptly notify at least one of the following listed persons at Wheelwright and Price, preferably in the priority of the listings:

WHEELWRIGHT

- 1) George Leatherman - Telephone 2861
- 2) Guy Baker - Telephone 2702
- 3) G. Hunter Thomas - Telephone 2371
- 4) Ellsworth Collins - Telephone 2585

PRICE

- 1) Earnest Halstead - Telephone 9-2411 or 9-2461
- 2) Howard Ferguson - Telephone 9-2411 or 9-2461
- 3) Earl Willis - Telephone 9-2231
- 4) Bobby Grimm - Telephone 9-2261

The men listed above, when notified that an emergency or alert exists, will put the following plan for each location into effect as rapidly as possible:

WHEELWRIGHT

The community is to be warned by a series of short blasts on the fire siren at the miners' bathhouse. This is to continue until the power is cut off by the following outlined action:

- 1) Blasting of the fire siren in accordance with the above is to be done by the attendant on duty at the bathhouse.
- 2) If no attendant is on duty at the bathhouse, a man will be immediately dispatched to operate the siren.
- 3) The two 2300-volt oil switches in the old substation building near the Wheelwright Mine portal are to be opened as quickly as possible. The 40,000-volt switches in the transformer yard serving the mine will be left closed.